



NOTE:

1. THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH THE CONTROLLER ELECTRICAL SCHEMATIC.
2. FOR COMPLIANCE WITH AS2941, ALL CABLES ENTERING CONTROLLER TERMINAL STRIP SHOULD BE NUMBERED.
3. FOR COMPLIANCE WITH AS3000, ALL SITE TERMINATIONS MADE TO THE CONTROLLER SHOULD BE UNDERTAKEN BY A QUALIFIED ELECTRICIAN.
4. VOLTAGE OF BELL & LIGHT MUST BE THE SAME AS CONTROLLER. THIS VOLTAGE WILL BE SPECIFIED ON THE IDENTITY PLATE LOCATED ON THE INSIDE OF THE CONTROLLER DOOR.

-	-	-	-	-	TO BE MODIFIED ON CAD ONLY	DRN.	D.R	25.01.11
-	-	-	-	-	SCALE :-	CHK.	S.B	25.01.11
-	-	-	-	-	PLOT SCALE :-	ENG.	S.B	25.01.11
B	NEW PCB NUMBERS	S.B	03.06.13	S.B	03.06.13	APP.	T.L	25.01.11
A	ISSUE FOR APPROVAL	D.R	25.01.11	S.B	25.01.11			
REV.	DESCRIPTION	DRN	DATE	CHK.	DATE.			

W&C
WELLING & CROSSLEY PTY LTD
39 EXPORT DR BROOKLYN VIC 3012
1042 CANLEY VALE RD WETHERSHILL
PARK NSW 2164
5/235 CAMBOON RD MALAGA WA 6090
2/55 CHRISTENSEN RD STAPLETON QLD 4207
53 ELIZABETH KNOX PLACE
MT WELLINGTON AUCKLAND
1072 NZ

CLIENT : -

THIS DRAWING AND DESIGN REMAIN THE PROPERTY OF WELLING & CROSSLEY PTY. LTD. A.B.N. 61 005 690 273. THIS DRAWING AND DESIGN CAN NOT BE COPIED OR ALTERED IN ANY WAY WITHOUT PRIOR WRITTEN APPROVAL FROM WELLING & CROSSLEY PTY. LTD. THIS DRAWING AND ALL COPIES, HARD & SOFT MUST BE RETURNED TO WELLING & CROSSLEY PTY. LTD. UPON REQUEST FROM WELLING & CROSSLEY PTY. LTD.

STANDARD DIESEL FIRE PUMP CONTROLLER				
ITEM	QTY	DESCRIPTION	W&C REF. No.	WT. Kg.
1	-	SOFTWARE VER 16.00	-	-
TITLE :		DIGITAL DIESEL TERMINATION VOLTS FREE DRAWING 1 OF 3		
DRG TYPE:		110125A		
		A3		REV B