

Maximum Power ratings: Power Ratings are Heat Exchanger Cooled, For Radiator Cooled Derate by 5%

FIRE RATINGS

(kW)

Production tolerance =+/-5%



| Model | 1400 | 1500 | 1600 | 1700 | 1800 | 1900 | 2000 | 2100 | 2200 | 2300 | 2400 | 2500 | 2600 | 2700 | 2800 | 2900 | 3000 |
|-------------------|------|------|------|-------|------|------|------|------|------|-------|------|-------|------|------|------|------|------|
| 380NC-FIRE 13 | NA | NA | 8 | 9 | 11 | 11.9 | 12.8 | 13.9 | 14.5 | 16 | 17 | 17.9 | 18.8 | 19.5 | 20 | 20.5 | 21 |
| 480N-FIRE 13 | NA | NA | 10 | 11.25 | 12.5 | 14 | 15 | 16 | 17 | 17.5 | 18.5 | 19.5 | 20.5 | 21.5 | 22.5 | 23.5 | 24 |
| 485N-FIRE 13 | NA | NA | 15 | 16 | 17.5 | 18.5 | 19.5 | 21 | 23 | 25 | 27.5 | 30 | 31 | 32 | 33 | 34 | 35 |
| 490N-FIRE 13 | NA | 23 | 25 | 26 | 28 | 29 | 31 | 32 | 33 | 34 | 35 | 38 | 39 | 40 | 41 | 41 | 41 |
| 4102N-1-FIRE 13 | NA | 36 | 38 | 40 | 44 | 46 | 47 | 48 | 49 | 50 | 52 | 52 | 53 | 53 | 53 | 53 | |
| 4102N-2-FIRE 13 | NA | 38 | 40 | 42 | 45 | 48 | 49 | 53 | 54 | 56 | 57 | 59 | 60 | 61 | 63 | 65 | |
| 4105T1-FIRE 13 | NA | NA | NA | NA | 60 | 63 | 67 | 68 | 70 | 72 | 73 | 75 | 76 | 78 | 80 | 80 | |
| 4105T2-FIRE 13 | NA | NA | NA | NA | 70 | 74 | 77 | 79 | 82 | 85 | 87 | 89 | 91 | 93 | 96 | 100 | |
| 4105T3-FIRE 13 | NA | NA | NA | NA | 70 | 74 | 78 | 80 | 85 | 87 | 92 | 96 | 100 | 104 | 108 | 110 | |
| 6102T2-FIRE 13 | NA | NA | NA | NA | NA | 110 | 120 | 122 | 124 | 128.5 | 129 | 129.5 | 130 | 130 | 130 | | |
| 6108T1-FIRE 13 | NA | 80 | 90 | 100 | 115 | 120 | 125 | 130 | 133 | 136 | 140 | 145 | 146 | 147 | 147 | | |
| 6120T-FIRE 13 | NA | NA | 144 | 150 | 156 | 162 | 166 | 170 | 175 | 177 | 179 | 180 | 180 | | | | |
| 6120Ti-FIRE 13 | NA | 160 | 170 | 180 | 190 | 195 | 200 | 201 | 202 | 203 | 204 | 206 | 208 | | | | |
| 6126Ti-1-FIRE 13 | NA | 180 | 209 | 218 | 227 | 236 | 245 | 245 | 245 | 245 | 245 | | | | | | |
| 6126Ti-2-FIRE 13 | NA | 200 | 225 | 240 | 253 | 268 | 275 | 280 | 280 | 280 | 280 | | | | | | |
| 6126Ti-2F-FIRE 13 | NA | 250 | 264 | 278 | 292 | 296 | 310 | 320 | 320 | 320 | 320 | | | | | | |
| 6126Ti-2L-FIRE 13 | NA | 288 | 302 | 316 | 332 | 348 | 360 | 376 | 380 | 380 | 380 | | | | | | |



| Model | 1400 | 1500 | 1600 | 1700 | 1800 | 1900 | 2000 | 2100 | 2200 | 2300 | 2400 | 2500 | 2600 | 2700 | 2800 | 2900 | 3000 |
|------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| LPW2-46 13 | NA | 7.5 | 8.4 | 9.3 | 10.2 | 10.3 | 10.6 | 10.6 | 10.7 | 11.2 | 11.8 | 13 | 13.7 | 13.9 | 14.1 | 14.4 | 14.7 |
| LPW3-46 13 | NA | 11.3 | 12.6 | 14 | 15.3 | 15.5 | 16 | 16.4 | 17.6 | 18.2 | 19 | 19.5 | 19.9 | 20.6 | 21 | 21.7 | 22.1 |
| LPW4-46 13 | NA | 15 | 16.8 | 18.6 | 20.5 | 20.9 | 21.2 | 21.5 | 22.1 | 22.8 | 24.7 | 26 | 26.3 | 27.7 | 28.2 | 29.1 | 29.5 |
| LPWT4-46 13 | NA | 22.7 | 23.8 | 24.9 | 26.1 | 28.8 | 31.5 | 33.2 | 34.6 | 35 | 36.2 | 37.7 | 38.8 | 39.4 | 40.2 | 40.9 | 41.6 |
| D1146N-FIRE 13 | NA | 90 | 93 | 95 | 101 | 106 | 111 | 115 | 120 | 122 | 122 | 122 | 122 | 122 | 122 | | |
| D1146NS-FIRE 13 | NA | 98 | 100 | 105 | 110 | 116 | 120 | 124 | 128 | 130 | 134 | 136 | 138 | 140 | 143 | | |
| D1146T-FIRE 13 | NA | 107 | 117 | 121 | 129 | 133 | 139 | 142 | 148 | 151 | 152 | 153 | 153 | 153 | 153 | | |
| D1146TS-FIRE 13 | NA | 110 | 121 | 126 | 133 | 139 | 145 | 147 | 153 | 155 | 157 | 161 | 164 | 166 | 170 | | |
| D1146TSS-FIRE 13 | NA | 120 | 127 | 133 | 140 | 147 | 155 | 160 | 164 | 169 | 174 | 180 | 183 | 187 | 190 | | |
| P086Ti-FIRE 13 | NA | 199 | 207 | 216 | 223 | 223 | 223 | 223 | 223 | | | | | | | | |
| P086TiS-FIRE 13 | NA | 200 | 208 | 217 | 223 | 230 | 238 | 246 | 252 | 258 | 261 | 265 | | | | | |
| PT86Ti-FIRE 13 | NA | 207 | 218 | 229 | 238 | 249 | 267 | 280 | | | | | | | | | |
| P126Ti-FIRE 13 | NA | 272 | 280 | 291 | 298 | 298 | 298 | 298 | | | | | | | | | |
| P126TiS-FIRE 13 | NA | 272 | 295 | 318 | 342 | 342 | 342 | 342 | | | | | | | | | |
| P158LE-FIRE 13 | NA | 414 | 423 | 434 | 443 | | | | | | | | | | | | |
| DP158LC-FIRE 13 | NA | 449 | 470 | 492 | 513 | | | | | | | | | | | | |
| DP158LD-FIRE 13 | NA | 510 | 525 | 540 | 556 | | | | | | | | | | | | |
| DP180LA-FIRE 13 | NA | 552 | 573 | 595 | 616 | | | | | | | | | | | | |
| DP180LB-FIRE 13 | NA | 612 | 628 | 645 | 661 | | | | | | | | | | | | |
| DP222LA-FIRE 13 | NA | 600 | 613 | 626 | 737 | | | | | | | | | | | | |
| DP222LB-FIRE 13 | NA | 664 | 704 | 744 | 782 | | | | | | | | | | | | |
| DP222LC-FIRE 13 | NA | 723 | 758 | 793 | 828 | | | | | | | | | | | | |

Rating Definition

Standby fire pump ratings represent the output that may be utilized to drive a stationary fire pump when the pumping equipment has been sized correctly according to and AS2941-2013

2 YEAR WARRANTY: 24 months from date of commissioning or 30 months from date of supply, whichever occurs first

| | | | | | |
|--|---|---|---|--|--|
| <p>Victoria: Head Office 59 Export Drive Brooklyn VIC 3012 P: 03 9316 9700 F: 03 9314 0909 E: sales@wellcross.com.au</p> | <p>New South Wales Unit 2/1040 Canley Vale Road Wetherill Park NSW 2164 P: 02 9757 5800 F: 02 9757 5899 E: nsw@wellcross.com.au</p> | <p>Queensland Unit 2/55 Christensen Rd Staplyton QLD 4207 P: 07 3386 2400 F: 07 3386 1241 E: qld@wellcross.com.au</p> | <p>North Queensland Unit 19/547 Industry Park 547-593 Woolcock St Mount Louisa, Townsville, QLD 4814 P: 07 4774 6331 E: nthqld@wellcross.com.au</p> | <p>Western Australia Unit 8/235 Camboon Road Malaga WA 6090 P: 08 9248 2955 F: 08 9248 2933 E: wa@wellcross.com.au</p> | <p>South Australia M: 0417 592 530 E: bnicholas@wellcross.com.au</p> |
|--|---|---|---|--|--|