




TERMINATIONS

- 240VAC ACTIVE ENGINE HEATER
- 240VAC NEUTRAL ENGINE HEATER
- JACKET HEATER ALARM SWITCH
- JACKET HEATER ALARM SWITCH
- E. EARTH ENGINE HEATER

WIRE NUMBERS

MUST BE FITTED TO ALL CABLES ENTERING CONTROLLER
TERMINAL STRIPS FOR COMPLIANCE WITH AS2941

CRANK ISOLATE SWITCH

WILL DISABLE THE CONTROLLER ENGINE CRANK CIRCUIT IN THE ISOLATE POSITION.
AUTOMATIC PRESSURE SWITCH STARTING AND CONTROLLER MANUAL STARTING IS DISABLED.
IF ENGINE IS RUNNING, IT IS NOT STOPPED.
ENGINE CAN STILL BE STARTED USING THE EMERGENCY MANUAL START BUTTONS LOCATED
BELOW THE CONTROLLER FASCIA.
PLACING THIS SWITCH IN THE ISOLATE POSITION WILL GENERATE A CONTROLLER ALARM CONDITION.

THIS CONTROLLER MUST BE SUPPLIED WITH 240V 10A CONTINUOUSLY FOR PROPER SYSTEM OPERATION.


FAILURE TO DO SO WILL CAUSE LOW BATTERY VOLTAGE
AND SYSTEM FAILURE WITHIN DAYS.
DISCONNECT BATTERIES IF 240V IS NOT CONNECTED.

IF MAINS HAS FAILED, AFTER 15 MINS. OF SYSTEM STANDBY, SYSTEM WILL ENTER POWERSAVE MODE.

IN THIS MODE:
SYSTEM DISPLAY WILL SWITCH OFF.
INDICATOR LIGHTS WILL SWITCH OFF, EXCEPT FOR POWER AVAILABLE AND CHARGER SUPPLY FAIL
WHICH WILL FLASH OUT OF SEQUENCE TO INDICATE POWERSAVE MODE IS ACTIVATED.
VOLT-FREES WILL CONTINUE TO OPERATE AS USUAL.
PRESS ANY FASCIA BUTTON TO DISABLE POWERSAVE MODE, AND SYSTEM WILL RESUME AS PREVIOUSLY.
NOTE: WHILST PANEL IS IN POWERSAVE MODE, THE DIESEL ENGINE WILL STILL START/STOP
WHEN REMOTELY CALLED TO. ALL VOLT-FREES WILL CONTINUE TO OPERATE.

REMOTE STOP

IS NOT LEGAL FOR COMPLIANCE WITH AS2941-13 IN SOME AUSTRALIAN STATES
CHECK WITH LOCAL AUTHORITIES BEFORE CONNECTING.



STANDARD DIESEL FIRE PUMP CONTROLLER				
1	-	SOFTWARE VER 18.00	-	-
ITEM	QTY	DESCRIPTION	W&C REF. No.	Wt. Kg.

TITLE : PCB CONNECTION
DRW 2 OF 3
AS2941-13 (NR500 START RELAY)

DRG No: 140320B-1
A3 REV C

REV.	DESCRIPTION	DRN	DATE	CHK.	DATE.
-	-	-	-	-	-
-	-	-	-	-	-
C	CHANGE TO NR500 RELAY	S.B.	09.07.26	S.B.	09.07.26
B	ISSUED FOR MANUFACTURE	S.B.	03.05.17	P.M.	03.05.17
A	ISSUE FOR APPROVAL	S.B.	20.03.14	S.B.	20.03.14
DRN	DATE	CHK.	DATE.		

W&C
WELLING & CROSSLEY PTY LTD
59 EXPORT DRIVE BROOKLYN VIC. 3012
1042 CANLEY VALE RD WETHERILL PARK NSW 2164
UNIT 5/235 CAMBOON RD MALAGA WA 6090
2/55 CHRISTENSEN RD STAPLTON QLD 4207
EMAIL: wellcross@wellcross.com.au

THIS DRAWING AND DESIGN REMAIN THE PROPERTY OF
WELLING & CROSSLEY PTY. LTD. A.B.N. 61 005 690 273.
THIS DRAWING AND DESIGN CAN NOT BE COPIED OR
ALTERED IN ANY WAY WITHOUT PRIOR WRITTEN
APPROVAL FROM WELLING & CROSSLEY PTY. LTD.
THIS DRAWING AND ALL COPIES, HARD & SOFT MUST BE
RETURNED TO WELLING & CROSSLEY PTY. LTD. UPON
REQUEST FROM WELLING & CROSSLEY PTY. LTD.